



Product Service

CERTIFICATE

No. Z2 115688 0002 Rev. 00

Holder of Certificate: CEEG(jiangsu)Tech Co., Ltd

No. 69, Feitian Avenue
Jiangning Airport Economic
Development Zone
210000 Nanjing
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product:

**Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module**

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 701262205601-00

Valid until: 2026-08-02

Date, 2022-03-28

(David Bo)



Product Service

CERTIFICATE

No. Z2 115688 0002 Rev. 00

Model(s):

CSUNxxx-144M (xxx=525-555, in step of 5);
CSUNxxx-120M (xxx=440-460, in step of 5);
CSUNxxx-108M (xxx=395-410, in step of 5);
CSUNxxx-96M (xxx=350-370, in step of 5);
CSUN315-84M, CSUN320-84M;
CSUNxxx-72M (xxx=265-275, in step of 5);
CSUNxxx-60M (xxx=220-230, in step of 5);
CSUN205-56M, CSUN210-56M;
CSUN190-52M, CSUN195-52M;
xxx is standing for rated output power at STC.

Parameters:

Safety Class:	Class II
Max. System Voltage:	1500V DC
Test Laboratory:	Changzhou HuaYang Inspection and Testing Technology Co., Ltd. No.8 Lanxiang Road, Wujin Economic Development Zone, Changzhou, Jiangsu, P.R. China
Construction:	Framed, with Junction box, cable and connector.
Fire Safety Class:	Class C according to UL790

Tested according to:

IEC 61215-1(ed.1)
IEC 61215-1-1(ed.1)
IEC 61215-2(ed.1)
IEC 61730-1(ed.2)
IEC 61730-2(ed.2)